

PRICE SCHEDULE

PROCUREMENT OF 02 KVA UPS AT DIFFERENT LOCATIONS OF NBP PAKISTAN.

S. No.	Description	Quantity (a)	Unit (b)	Unit Rate (c) (Pak Rupees)	Total (a x c) (Pak Rupees)
1.	UPS Supply, Installation, testing and commissioning of 02KVA UPS. Line interactive, long backup, Pure sine wave, Input voltage: 165-275VAC, Input Frequency: 46-56Hz, Out Put voltage: 220/230VAC, Output frequency: 50Hz, VDC: 24, Transfer time: 0ms, Power factor: 0.7. Make: Power edge, Delux, MZ, Dynamic or equivalent including 10 Rft cable of 6mm² (Pakistan cable, Fast, Newage or equivalent) and 16A Circuit breaker (Schiender, Terasaki, ABB or equivalent) Model No: _____ Brand Name: _____ UPS Power Rating: _____ Name of Manufacturer: _____ Country of Origin: _____	30	Nos.		
2.	BATTERIES Supply, Installation, testing and commissioning of Batteries for above UPS. Rating: 12V,(2x185Ah), Dry Sealed Lead Acid Maintenance Free. Make: Long, Leoch, Lido, Narada or equivalent. Battery Rating: _____ Model No: _____ Brand Name: _____ Name of Manufacturer: _____ Country of Origin: _____	30	Nos.		

Continued

PRICE SCHEDULE

SUPPLY AND INSTALLTION OF 02 KVA UPS FOR DIFFERENT NBP BRANCHES ACROSS PAKISTAN

S. No.	Description	Quantity (a)	Unit (b)	Unit Rate (c) (Pak Rupees)	Total (a x c) (Pak Rupees)
3.	MAIN POWER CABLING Supply, Laying and connection of Cu/PVC/PVC Cables (Pakistan/Fast or Equivalent Make), 6mm ² , 3-core.	30	Jobs		
4.	MINIATURE CIRCUIT BREAKER (MCB) Supply, Installation and connection of miniature circuit breaker of 16A, Make: Scheinder, Terasaki, ABB or equivalent.	30	Nos.		

Amount in Words

(Rs. _____)

- The quoted rates / amount shall be inclusive of all applicable Federal/Provincial Govt. Taxes/Duties and charges for inland transportation and other related services etc.
- The material upon delivery at the site should be got verified from the Bank Engineer, prior to its installation at site. Otherwise, Bank Engineer reserves the right to replace the same without incurring any liability or payment of any charges to the bidder.