


TECHNICAL SPECIFICATIONS**LED Lights FOR FIAP**

Description of Items	SAMPLE PICTURE
<u>LED Panel Lights</u> <u>SPECIFICATION:</u> LED Panel Lights Recessed / surface-mount LED backlit panel light for uniform, glare-free illumination suitable for offices and airport passenger halls. The technical specifications are as under: • Size: 2 ft. x 2 ft. • Power Supply: 220-240V 50Hz • Wattage: 36-40 Watt • Color Temperature: 3000K $\pm$ 100K • IP Rating: IP20 (standard, indoor dry location) • Warranty Period: 1 year (standard warranty) Note: Sample of the item to be approved by the E&M section FIAP prior to making final order by the Contractor/ Supplier to avoid any complications during installation.	

(b)	LED Down Lights Recessed / surface-mount LED down light for uniform, glare-free illumination suitable for washrooms. The technical specifications are as under: • Power Supply: 220-240V 50Hz • Wattage: 18-20 Watt • Color Temperature: 6500K ± 100K • IP Rating: IP20 (standard, indoor dry location) • Warranty Period: 1 year (standard warranty) Note: Sample of the item to be approved by the E/M section FIAP prior to making final order by the Contractor/ Supplier to avoid any complications during installation.	
	Important Note: ➤ Quality & Warranty: Procured LED Lights must be of superior quality, including a comprehensive one-year warranty that covers replacement of any faulty light. ➤ Technical Documentation: Bidders must attach official technical literature, brochures, brand details, and high-resolution color photographs of all quoted items to their technical bids. ➤ Taxation & Local Presence: Financial quotes must be fully inclusive of all applicable taxes. Bidders are required to submit physical product samples alongside their technical bids. ➤ Manufacturer Authorization: Original Equipment Manufacturers (OEMs) may authorize a representative bidder. A valid, authentic OEM authorization letter must be enclosed with the technical bid submission. ➤ Product Sample: All participating bidders shall provide samples (Qty 1) of all quoted items at the time of technical bid opening. The samples are to be approved by E&M section prior to final order. All cost of sample submission shall be borne by the bidder with no cost to PAA.	

Bidders: _____
(Signed and Stamped)