


Approved date for Lugs.

See Comment
No. A) b) 1)

Part No.	Dimension (mm)				
	Φ	D	d	U1	L
HD-LG2-25	10.5	10	7	44.5	120
HD-LG2-35	10.5	11	8	44.5	125
HD-LG2-50	10.5	13	10	44.5	135
HD-LG2-70	12.5	16	11.5	44.5	140
HD-LG2-95	12.5	18	13.5	44.5	145
HD-LG2-120	12.5	20	15	44.5	150
HD-LG2-150	16.5	22	15	44.5	156
*** HD-LG2-185	16.5	25	18.5	44.5	160
HD-LG2-240	16.5	27	21	44.5	160



Materials:
Lug: Copper
Bolts: silicon bronze

Project: 500/220/132kV Rahim Yar Khan substation

						Zhejiang Huadian Lightning Protection Technology Co., Ltd. China	
MARK						2013.4.17	
DESIGN	ZHU CH	standardization		Phase Marker		weight	scale
CHECK	ZHANG HS						1:1
TECHNICS	ZHU CH	authorize		HUANG HL		DRAWING NO.: HD-TL-13048-WU-2	
				PAGE 1-1			