

1. Name Package: NCB-811/FESCO/PMU/GSC/2026-27

2. List of Goods and Related Services:

S #	Description	Unit	Qty
1	132KV P.T 132000/110 Volt with Steel Supporting Structure, Terminal Connectors & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	09
2	145 KV Current Transformer 800:400/1 Amp along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	03
3	132kV, 40kA, Single Phase Metering C.Ts Ratio 1200:600/1 Amp, Accuracy Class 0.2sFS5 along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	06
4	132kV Voltage Transformers (Grid Metering) Accuracy Class 0.2, Ratio 132kV/√3/110/√3 Single Phase Single Core with extended creepage distance along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	06

Note: Bidder shall quote full quantity of each item, in case, a bidder does not quote complete tender (i.e. all quantities of each item of the tender), the bidder shall be considered non responsive in the tender during tender evaluation.

3. Delivery and Completion Schedule

S#	Description of Goods	DeliverySchedule (FCS)Project Site/FESCO Store	Location
1	132KV P.T 132000/110 Volt with Steel Supporting Structure, Terminal Connectors & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	150-Days from signing of contract	FESCO / Central Ware house Nishatabad Faisalabad or any FESCO Project site
2	145 KV Current Transformer 800:400/1 Amp along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)		
3	132kV, 40kA, Single Phase Metering C.Ts Ratio 1200:600/1 Amp, Accuracy Class 0.2sFS5 along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)		
4	132kV Voltage Transformers (Grid Metering) Accuracy Class 0.2, Ratio 132kV/√3/110/√3 Single Phase Single Core with extended creepage distance along with Steel Supporting Structures, Terminal Clamps & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)		

SEAL & SIGNATURE OF BIDDER

NCB-811/FESCO/PMU/GSC/2026-27Procurement of Material

Director (Procurement)
PMU, FESCO, Faisalabad