

1. Name Package: NCB-857/FESCO/PMU/GSC(DEPOSIT-WORK)//2026-27

2. List of Goods and Related Services:

S #	Description	Unit	Qty
1	132KV Transformer C.Ts 100:200/5-5-5 Amp along with Steel Supporting Structure, Terminal Clamps & grouting bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	09
2	132KV P.T 132000/110 Volt with Steel Supporting Structure, Terminal Connectors & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	09
3	132KV Line C.Ts ratio 1200:600:300/5-5-5-5 Amp with Steel Supporting Structure, grouting bolts and terminal connector as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	Nos.	18
4	11 KV Neutral C-T 50/5 Amp	No.	03


Note: Bidder shall quote full quantity of each item, in case, a bidder does not quote complete tender (i.e. all quantities of each item of the tender), the bidder shall be considered non responsive in the tender during tender evaluation.

3. Delivery and Completion Schedule

S#	Description of Goods	DeliverySchedule (FCS)Project Site/FESCO Store	Location
1	132KV Transformer C.Ts 100:200/5-5-5 Amp along with Steel Supporting Structure, Terminal Clamps & grouting bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)	150-Days from signing of contract	FESCO / Central Ware house Nishatabad Faisalabad or any FESCO Project site
2	132KV P.T 132000/110 Volt with Steel Supporting Structure, Terminal Connectors & Grouting Bolts as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)		
3	132KV Line C.Ts ratio 1200:600:300/5-5-5-5 Amp with Steel Supporting Structure, grouting bolts and terminal connector as per concerned WAPDA/PEPCO/NTDC Specification (amended to date)		
4	11 KV Neutral C-T 50/5 Amp		

SEAL & SIGNATURE OF BIDDER

NCB-857/FESCO/PMU/GSC(DEPOSIT-WORK)/2026-27Procurement of Material


Director Procurement
PMU, FESCO, Faisalabad